

Certificate

Hygiene conformity test

Tested type series Humifog

Device type high pressure atomizing humidifier

Manufacturer Carel SpA Headquarters, Via dell'Industria,11, I-35020 Brugine

Date and place of test 30th and 31th July 2008, Carel SpA Headquarters, I-35030 Brugine

Test criterion Hygiene requirements for the following standards:

Standard climatisation

VDI 6022, page 1 (04/06) ✓
VDI 3803 (10/02) ✓
ÖNORM H 6021 (09/03) ✓
SWKI VA104-01 (04/06) ✓
DIN EN 13779 (09/07) ✓

Hospitals

DIN 1946, part 4 (01/94) ✓
ÖNORM H 6020 (02/07) ✓*
SWKI 99-3 (03/04) ✓

* In accordance with H 6020 (02/07), chapter 6.13.2 is demanded in Austria the use of steam humidifiers or equivalent humidification systems.

Test result **Hygiene conformity is** not confirmed
 confirmed subject to conditions
 confirmed without conditions

Validity period 3 years: 08.2008 – 08.2011

Registration number HKP/II/050a/8/0808/0811/MZ



Expert appraiser: Dr.-Ing. M. Möritz

Berlin, 27th March 2009

Within the scope of the hygiene conformity test, the hygiene-relevant requirements of the regulations listed under the "test criteria" and marked with a "✓" were tested. Requirements referred to in other regulations were not tested. The hygiene conformity test does not include toxicological tests or assessments of the materials used in the tested equipment series.