



## Declaration of Conformity

Manufacturer: **CAREL Industries S.p.A.**

Via dell'Industria, 11 35020 Brugine (PD) Italy

### PJ EZ: electronic controller for static/ ventilated normal/ low temperature units

Code	Description
<b>PJ</b> abcdefgh	CAREL version PJEZ easy
<b>PZ</b> abcdefgh	customized version PJEZ easy
<b>aa:</b>	<b>EZ</b> = CAREL version alphanumeric characters= customized version
<b>b:</b>	<b>M</b> = 0 relais, <b>S</b> = 1 relay, <b>X</b> = 2 independent relais, <b>Y</b> = 2 relais, <b>C</b> = 3 relais
<b>c:</b>	<b>0</b> = NTC probes with buzzer, <b>1</b> = NTC probes, <b>2</b> = NTC probes with buzzer, <b>3</b> = NTC probes wide range, <b>6</b> = PTC probes with buzzer, <b>7</b> = PTC probes
<b>d:</b>	<b>N</b> = 0 relais (PJEZM), <b>O</b> = 8A, <b>D</b> = 8A+AUX(8A) (PJEZS), <b>P</b> = 16A, independent outputs relais, <b>R</b> = 16A+AUX(8A), RTC (PJEZS/Y), <b>H</b> = 2HP, independent outputs relais, <b>F</b> = 2HP+ AUX(8A), <b>A</b> = 8A+AUX(8A), independent outputs relais (PJEZS/Y), <b>T</b> = 16A+AUX(8A), <b>V</b> = 16A+AUX(8A) (PJEZS/Y), independent outputs relais, <b>G</b> = 2HP+AUX(8A), independent outputs relais (PJEZS/Y), <b>C</b> = 8A,RTC (PJEZX/Y/C), <b>S</b> = 16A,RTC (PJEZX/Y/C), <b>M</b> = 2HP, RTC (PJEZX/Y/C), <b>L</b> = 8A+AUX(8A) RTC (PJEZS/Y),RTC, <b>B</b> = 2HP+AUX (8A), RTC (PJEZS/Y), <b>Z</b> = entry level, white, no defrost
<b>e:</b>	<b>0</b> = 230 Vac red display, <b>1</b> = 115 Vac red display, <b>2</b> = 12 Vac red display, <b>G</b> = 230 Vac green display, <b>3</b> = 115 Vac green display, <b>4</b> = 12 Vac green display, <b>B</b> = 230 Vac blue display, <b>5</b> = 115 Vac blue display, <b>6</b> = 12 Vac blue display
<b>f:</b>	<b>0</b> = removable terminal blocks, with serial, 3 inputs, <b>1</b> = fixed terminal blocks, with serial, 3 inputs, <b>E</b> = fixed terminal blocks, 1 inp. PJEZM no keyboard, 1 inp. PJEZS, <b>2</b> = faston+ removable terminal blocks, with serial, 3 inputs, <b>3</b> = faston+ fixed terminal blocks, with serial, 3 inputs
<b>g:</b>	<b>0</b> = standard, <b>x</b> = alphanumeric character= customized version, <b>P</b> = single package with 1 probe HP(NTC) or WO(PTC) 1,5 mt. in length, <b>Q</b> = single package with 1 probe HP(NTC) or WO(PTC) 0,8 mt. in length, <b>W</b> = single package with 1 probe WP(NTC)1,5 mt. in length, <b>X</b> = single package with 1 probe WP(NTC) 0,8 mt. in length
<b>h:</b>	<b>blank</b> = single package std. CAREL, <b>K</b> = kit/ kit

The manufacturer declares that all the above indicated products are in accordance with the EC Directives:

**2004/108/EC (EMC) and 2006/95/EC (LVD)**

and comply with the requirements of the following European standards:

**EMC:** EN 55014-1, EN 55014/A1, EN 55014/A2, EN 55014-2, EN 55014/A1,  
EN 61326-1, EN 61326/A1, EN 61326/A2, EN 61326/A3,  
EN 61000-6-1, EN 61000-6-2, EN 61000-6-3, EN 61000-6-3/A11,  
EN 61000-6-4

**LVD:** EN 61010-1, EN 60730-2-9, EN 60730-2-9/A1, EN 60730-2-9/A11,  
EN 60730-1, EN 60730-1/A11, EN 60730-1/A12.

Brugine, 08<sup>th</sup> May 2012

CAREL INDUSTRIES S.p.A.  
Technical Director  
Ing. Umberto Bianchini

