

## Declaration of Conformity

Manufacturer: **CAREL Industries S.p.A.**  
 Via dell'Industria, 11 35020 Brugine (PD) Italy

### NTC – NTC passive temperature probes

| Code             | Description   |
|------------------|---|
| <b>NTCaabbcc</b> | NTC passive temperature probes  |
| <b>aaa:</b>      | <b>001 to 120=</b> code length of probe cable   |
| <b>bb:</b>       | <b>HP=</b> High performance type (plastic cap IP67)<br><b>HF=</b> High performance type with STRAP-ON<br><b>WP=</b> Water proof type (inox metal cap IP67)<br><b>WH=</b> New water proof type (inox metal cap IP67)<br><b>WF=</b> Water proof type (inox metal cap IP68)<br><b>HT=</b> High temperature type (inox metal or plastic cap IP55) |
| <b>cc:</b>       | <b>xx</b> – letter or numbers to identify secondary option (type of connection, colour...)  |

We hereby declares that all the above indicated products comply with the requirements of standard **IEC 60079-15 edition 4**, as required by the standards **EN 60335-2-24:2011**, **EN 60335-2-40/A1:2007** and **EN 60335-2-89:2011** in case of using hydrocarbon refrigeration gas (e.g. R290 Propane and R600a Isobutane).

Brugine, 11<sup>th</sup> August 2016

CAREL INDUSTRIES S.p.A.  
 Technical Director  
 Ing. *Umberto Bianchini*

