

Declaration of Conformity

SPKT pressure transducers

Code	Description
SPKT00abcd	Pressure transducer
a	0..9, A..Z = Pressure measurement range
b	1 = Port fitting 1/4 SAE, 7/16" UNF female flare – stainless steel 3, 6 = Port fitting 1/4 SAE, 7/16" UNF female flare - brass 8 = Port fitting 1/4 gas male – stainless steel
c	P, R = ratiometric pressure transducer S = ratiometric pressure transducer – high performances C, D = 4-20mA output pressure transducer
d	0 = Single packaging 1 = Multiple packaging

We hereby declares that all the above indicated products comply with the requirements of standard **IEC 60079-15 edition 4**, as required by the standards **EN 60335-2-24:2011**, **EN 60335-2-40/A1:2007** and **EN 60335-2-89:2011** in case of using hydrocarbon refrigeration gas (e.g. R290 Propane and R600a Isobutane).

Brugine, 11th August 2016

CAREL INDUSTRIES S.p.A.
 Technical Director
 Ing. *Umberto Bianchini*

